



# REGIONAL REVIEW NOTIFICATION

Atlanta Regional Commission • 40 Courtland Street NE, Atlanta, Georgia 30303 • ph: 404.463.3100 • fax: 404.463.3105 • [www.atlantaregional.com](http://www.atlantaregional.com)

**DATE:** May 5 2008

**ARC REVIEW CODE:** R805051

**TO:** Mayor Harold Logsdon  
**ATTN TO:** David Rast, Planning Director  
**FROM:** Charles Krautler, Director

NOTE: This is digital signature.  
Original on file.

The Atlanta Regional Commission (ARC) has received the following proposal and is initiating a regional review to seek comments from potentially impacted jurisdictions and agencies. The ARC requests your comments related to the proposal not addressed by the Commission's regional plans and policies.

**Name of Proposal:** SANY America

**Review Type:** Development of Regional Impact

**Description:** The proposed SANY America is a manufacturing plant located on 228 acres in the City of Peachtree City. The proposed development will consist of 139,930 square feet of office space, 322,917 square feet of Assembly/painting, and 107,639 square feet of distribution space. The proposed development is located west of GA 74 and southeast of Falcon Field.

**Submitting Local Government:** City of Peachtree City

**Date Opened:** May 5 2008

**Deadline for Comments:** May 19 2008

**Earliest the Regional Review can be Completed:** Jun 4 2008

## THE FOLLOWING LOCAL GOVERNMENTS AND AGENCIES ARE RECEIVING NOTICE OF THIS REVIEW:

ARC LAND USE PLANNING  
ARC DATA RESEARCH  
GEORGIA DEPARTMENT OF NATURAL RESOURCES  
FAYETTE COUNTY  
CHATTAHOOCHEE-FLINT RDC

ARC TRANSPORTATION PLANNING  
ARC AGING DIVISION  
GEORGIA DEPARTMENT OF TRANSPORTATION  
COWETA COUNTY  
CSX RAILROAD

ARC ENVIRONMENTAL PLANNING  
GEORGIA DEPARTMENT OF COMMUNITY AFFAIRS  
GEORGIA REGIONAL TRANSPORTATION AUTHORITY  
SENOIA COUNTY

## Attached is information concerning this review.

If you have any questions regarding this review, Please call Haley Fleming, Review Coordinator, at (404) 463-3311. If the ARC staff does not receive comments from you by 2008-05-19 00:00:00, we will assume that your agency has no additional comments and we will close the review. Comments by email are strongly encouraged.

The ARC review website is located at: <http://www.atlantaregional.com/landuse> .



# REGIONAL REVIEW NOTIFICATION

Atlanta Regional Commission • 40 Courtland Street NE, Atlanta, Georgia 30303 • ph: 404.463.3100 • fax:404.463.3105 • [www.atlantaregional.com](http://www.atlantaregional.com)



## DEVELOPMENT OF REGIONAL IMPACT

### DRI- REQUEST FOR COMMENTS

Instructions: The project described below has been submitted to this Regional Development Center for review as a Development of Regional Impact (DRI). A DRI is a development of sufficient project of sufficient scale or importance that it is likely to have impacts beyond the jurisdiction in which the project is actually located, such as adjoining cities or neighboring counties. We would like to consider your comments on this proposed development in our DRI review process. Therefore, please review the information about the project included on this form and give us your comments in the space provided. The completed form should be returned to the RDC on or before the specified return deadline.

Preliminary Findings of the RDC: **SANY America** *See the Preliminary Report* .

Comments from affected party (attach additional sheets as needed):

Individual Completing form:

Local Government:

Department:

Telephone: (     )

Signature:

Date:

***Please Return this form to:***

Haley Fleming, Atlanta Regional Commission  
40 Courtland Street NE  
Atlanta, GA 30303  
Ph. (404) 463-3311 Fax (404) 463-3254  
[hffleming@atlantaregional.com](mailto:hffleming@atlantaregional.com)


**Return Date: *May 19 2008***

Preliminary Report:	May 5, 2008	<b>DEVELOPMENT OF REGIONAL IMPACT REVIEW REPORT</b>	Project:	SANY America #1779
Final Report Due:	June 4, 2008		Comments Due By:	May 19, 2008

## PRELIMINARY REPORT SUMMARY

### PROPOSED DEVELOPMENT:

The proposed SANY America is a manufacturing plant located on 228 acres in the City of Peachtree City. The proposed development will consist of 139,930 square feet of office space, 322,917 square feet of Assembly/painting, and 107,639 square feet of distribution space. The proposed development is located west of GA 74 and southeast of Falcon Field.



### PROJECT PHASING:

The project is being proposed in one phase with a project build out date for 2010.

### GENERAL

According to information on the review form or comments received from potentially affected governments:

**Is the proposed project consistent with the host-local government's comprehensive plan? If not, identify inconsistencies.**

The project site is currently zoned General Industrial and no zoning change is required. Information submitted for the review states that the proposed development is consistent with the City of Peachtree City's Future Land Use Map, which designates the areas as employment center-industrial.

**Is the proposed project consistent with any potentially affected local government's comprehensive plan? If not, identify inconsistencies.**

This will be determined based on comments received from potentially impacted local governments.

**Will the proposed project impact the implementation of any local government's short-term work program? If so, how?**

This will be determined based on comments received from potentially impacted local governments.

**Will the proposed project generate population and/or employment increases in the Region? If yes, what would be the major infrastructure and facilities improvements needed to support the increase?**

Yes, the proposed development would increase the need for services in the area for existing and future employees.

**What other major development projects are planned near the proposed project?**

<b>Preliminary Report:</b>	May 5, 2008	<b>DEVELOPMENT OF REGIONAL IMPACT <u>REVIEW REPORT</u></b>	<b>Project:</b>	SANY America #1779
<b>Final Report Due:</b>	June 4, 2008		<b>Comments Due By:</b>	May 19, 2008

The ARC has reviewed other major development projects, known as Area Plan (1984 to 1991) or as a DRI (1991 to present), within a 10 mile radius of the proposed project.

<b>YEAR</b>	<b>NAME</b>
2006	West Village
2000	Shoal Creek WRF Replacement
1997	Crowning Pointe
1996	Wieland Tyrone PUD

**Will the proposed project displace housing units or community facilities? If yes, identify and give number of units, facilities, etc.**

Information submitted for the review, the site is currently undeveloped.

**Will the development cause a loss in jobs? If yes, how many?**

No.

**Is the proposed development consistent with regional plans and policies?**

According to the Unified Growth Policy Map, the proposed development is located in an area designated as a suburban neighborhood. Suburban Neighborhoods are defined as distinct areas that are located in an urban area that are developed at a suburban scale with appropriate commercial development. The site is also located within a Regional Freight Area. Regional Freight Areas are strategic freight areas that are existing freight or industrial uses.

Information submitted for the review states that the proposed development is seeking Leadership in Energy and Environmental Design (LEED) certification. LEED certification is the nationally accepted certification for Green Building design, construction, and operation. With LEED certification, and being develop in Regional Freight Area, this development meets many Regional Development Plan Policies.

<b>Preliminary Report:</b>	May 5, 2008	<b>DEVELOPMENT OF REGIONAL IMPACT <u>REVIEW REPORT</u></b>	<b>Project:</b>	SANY America #1779
<b>Final Report Due:</b>	June 4, 2008		<b>Comments Due By:</b>	May 19, 2008

## **PRELIMINARY REPORT**

### **Regional Development Plan Policies**

1. Provide sustainable economic growth in all areas of the region.
2. Encourage new homes and jobs within existing developed areas of the region, focusing on principal transportation corridors, the Central Business District, activity centers, and town centers.
3. Increase opportunities for mixed use development, transit-oriented development, infill, and redevelopment.
4. At strategic regional locations, plan and retail industrial and freight land uses.
5. Design transportation infrastructure to protect the context of adjoining development and provide a sense of place appropriate for our communities.
6. Promote the reclamation of Brownfield development sites.
7. Protect the character and integrity of existing neighborhoods, while also meeting the needs of communities to grow.
8. Encourage a variety of homes styles, densities, and price ranges in locations that are accessible to jobs and services to ensure housing for individuals and families of all incomes and age groups.
9. Promote new communities that feature greenspace and neighborhood parks, pedestrian scale, support transportation options, and provide an appropriate mix of uses and housing types.
10. Promote sustainable and energy efficient development.
11. Protect environmentally-sensitive areas including wetlands, floodplains, small water supply watersheds, rivers and stream corridors.
12. Increase the amount, quality, and connectivity, and accessibility of greenspace.
13. Provide strategies to preserve and enhance historic resources
14. Through regional infrastructure planning, limit growth in undeveloped areas of the region
15. Assist local governments to adopt growth management strategies that make more efficient use of existing infrastructure.
16. Inform and involve the public in planning at regional, local, and neighborhood levels.
17. Coordinate local policies and regulations to support Regional Policies
18. Encourage the development of state and regional growth management policy.

### **BEST LAND USE PRACTICES**

Practice 1: Keep vehicle miles of travel (VMT) below the area average. Infill developments are the best at accomplishing this. The more remote a development the more self contained it must be to stay below the area average VMT.

Practice 2: Contribute to the area's jobs-housing balance. Strive for a job-housing balance with a three to five mile area around a development site.

Practice 3: Mix land uses at the finest grain the market will bear and include civic uses in the mix.

<b>Preliminary Report:</b>	May 5, 2008	<b>DEVELOPMENT OF REGIONAL IMPACT REVIEW REPORT</b>	<b>Project:</b>	SANY America #1779
<b>Final Report Due:</b>	June 4, 2008		<b>Comments Due By:</b>	May 19, 2008

Practice 4: Develop in clusters and keep the clusters small. This will result in more open space preservation.

Practice 5: Place higher-density housing near commercial centers, transit lines and parks. This will enable more walking, biking and transit use.

Practice 6: Phase convenience shopping and recreational opportunities to keep pace with housing. These are valued amenities and translate into less external travel by residents if located conveniently to housing.

Practice 7: Make subdivisions into neighborhoods with well-defined centers and edges. This is traditional development.

Practice 8: Reserve school sites and donate them if necessary to attract new schools. This will result in neighborhood schools which provide a more supportive learning environment than larger ones.

Practice 9: Concentrate commercial development in compact centers or districts, rather than letting it spread out in strips.

Practice 10: Make shopping centers and business parks into all-purpose activity centers. Suburban shopping centers and their environs could be improved by mixing uses and designing them with the pedestrian amenities of downtowns.

Practice 11: Tame auto-oriented land uses, or at least separate them from pedestrian-oriented uses. Relegate “big box” stores to areas where they will do the least harm to the community fabric.

## BEST TRANSPORTATION PRACTICES

Practice 1: Design the street network with multiple connections and relatively direct routes.

Practice 2: Space through-streets no more than a half mile apart, or the equivalent route density in a curvilinear network.

Practice 3: Use traffic-calming measures liberally. Use short streets, sharp curves, center islands, traffic circles, textured pavements, speed bumps and raised crosswalks.

Practice 4: Keep speeds on local streets down to 20 mph.

Practice 5: Keep speeds on arterials and collectors down to 35 mph (at least inside communities).

Practice 6: Keep all streets as narrow as possible and never more than four traffic lanes wide. Florida suggests access streets 18 feet, subcollectors 26 feet, and collectors from 28 feet to 36 feet depending on lanes and parking.

Practice 7: Align streets to give buildings energy-efficient orientations. Allow building sites to benefit from sun angles, natural shading and prevailing breezes.

Practice 8: Avoid using traffic signals wherever possible and always space them for good traffic progression.

Practice 9: Provide networks for pedestrians and bicyclists as good as the network for motorists.

Practice 10: Provide pedestrians and bicyclists with shortcuts and alternatives to travel along high-volume streets.

Practice 11: Incorporate transit-oriented design features.

Practice 12: Establish TDM programs for local employees. Ridesharing, modified work hours, telecommuting and others.

## BEST ENVIRONMENTAL PRACTICES

Practice 1: Use a systems approach to environmental planning. Shift from development orientation to basins or ecosystems planning.

Practice 2: Channel development into areas that are already disturbed.

Practice 3: Preserve patches of high-quality habitat, as large and circular as possible, feathered at the edges and connected by wildlife corridors. Stream corridors offer great potential.

Practice 4: Design around significant wetlands.

Practice 5: Establish upland buffers around all retained wetlands and natural water bodies.

Practice 6: Preserve significant uplands, too.

Practice 7: Restore and enhance ecological functions damaged by prior site activities.

Practice 8: Detain runoff with open, natural drainage systems. The more natural the system the more valuable it will be for wildlife and water quality.

Practice 9: Design man-made lakes and stormwater ponds for maximum environmental value. Recreation, stormwater management, wildlife habitat and others.

<b>Preliminary Report:</b>	May 5, 2008	<b>DEVELOPMENT OF REGIONAL IMPACT <u>REVIEW REPORT</u></b>	<b>Project:</b>	SANY America #1779
<b>Final Report Due:</b>	June 4, 2008		<b>Comments Due By:</b>	May 19, 2008

Practice 10: Use reclaimed water and integrated pest management on large landscaped areas. Integrated pest management involves controlling pests by introducing their natural enemies and cultivating disease and insect resistant grasses.

Practice 11: Use and require the use of Xeriscape™ landscaping. Xeriscaping™ is water conserving landscape methods and materials.

## **BEST HOUSING PRACTICES**

Practice 1: Offer “life cycle” housing. Providing integrated housing for every part of the “life cycle”.

Practice 2: Achieve an average net residential density of six to seven units per acre without the appearance of crowding. Cluster housing to achieve open space.

Practice 3: Use cost-effective site development and construction practices. Small frontages and setbacks; rolled curbs or no curbs; shared driveways.

Practice 4: Design of energy-saving features. Natural shading and solar access.

Practice 5: Supply affordable single-family homes for moderate-income households.

Practice 6: Supply affordable multi-family and accessory housing for low-income households.

Practice 7: Tap government housing programs to broaden and deepen the housing/income mix.

Practice 8: Mix housing to the extent the market will bear.

## **LOCATION**

### **Where is the proposed project located within the host-local government's boundaries?**

The proposed development is located in the City of Peachtree City, west of GA 74 and southeast of Falcon Field.

### **Will the proposed project be located close to the host-local government's boundary with another local government? If yes, identify the other local government.**

The proposed development is entirely within the City of Peachtree City; however the proposed development is adjacent to Coweta County and the City of Senoia.

### **Will the proposed project be located close to land uses in other jurisdictions that would benefit, or be negatively impacted, by the project? Identify those land uses which would benefit and those which would be negatively affected and describe impacts.**

To be determined during the review.

## **ECONOMY OF THE REGION**

According to information on the review form or comments received from potentially affected governments:

### **What new taxes will be generated by the proposed project?**

Estimated value of the development is \$70,000,000 with an expected \$30,000,000 in annual local tax revenues.

Preliminary Report:	May 5, 2008	<b>DEVELOPMENT OF REGIONAL IMPACT <u>REVIEW REPORT</u></b>	Project:	SANY America #1779
Final Report Due:	June 4, 2008		Comments Due By:	May 19, 2008

**How many short-term jobs will the development generate in the Region?**

Short-term jobs will depend upon construction schedule.

**Is the regional work force sufficient to fill the demand created by the proposed project?**

Yes.

**In what ways could the proposed development have a positive or negative impact on existing industry or business in the Region?**

To be determined during the review.

**NATURAL RESOURCES**

**Water Supply Watersheds and Stream Buffers**

The project property abuts Line Creek. It is located downstream of both the Fayette County and City of Newnan water supply intakes and therefore is not in a water supply watershed. In addition to Line Creek, which forms the southern boundary of the project property, the USGS regional coverage shows three unnamed perennial and intermittent streams on the property, which are also shown on the project plans. The City of Peachtree City has an adopted stream buffer ordinance which requires a 50-foot undisturbed vegetative buffer and an additional 25-foot impervious surface setback (total 75 feet) on all perennial streams as defined in the ordinance. The buffer and setback are shown on Line Creek and the mapped tributaries. The Georgia EPD's 25-foot erosion and sedimentation buffer is also shown along these streams. The State 25-foot buffer is also required on all state waters on the property.

The site plan shows a proposed structure, identified as Assembly #1, and its access drives located over one of the unnamed mapped tributaries. It is also shown as partially covering wetlands at the headwaters of the aforementioned stream. If this portion of the project is built as shown in this location, it will require a variance from Peachtree City for the stream buffer intrusion, variances from Georgia EPD for the 25-foot erosion and sedimentation buffer intrusion and work in state waters and a Section 404 permit from the US Army Corps of Engineers for work in the wetlands and stream. No mitigation is shown on the plans.

**Storm Water/Water Quality**

The project should adequately address the impacts of the proposed development on stormwater runoff and downstream water quality. During construction, the project should conform to the relevant state and federal erosion and sedimentation control requirements. After construction, water quality will be impacted due to polluted stormwater runoff. ARC has estimated the amount of pollutants that will be produced after construction of the proposed development, using impervious areas based on estimated averages for land uses in the Atlanta Region. The actual amount of impervious surface may vary, which will affect the actual loadings. The Forest/Open acreage is based on the 100-year floodplain



<b>Preliminary Report:</b>	May 5, 2008	<b>DEVELOPMENT OF REGIONAL IMPACT REVIEW REPORT</b>	<b>Project:</b>	SANY America #1779
<b>Final Report Due:</b>	June 4, 2008		<b>Comments Due By:</b>	May 19, 2008

acreage shown on the plans, the only open space acreage provided. The following table summarizes the results of the analysis:

Land Use	Pollutant loads (lb./yr.)						
	Land Area (acres)	TP	TN	BOD	TSS	Zinc	Lead
Forest/Open	77.00	6.16	46.20	693.00	18095.00	0.00	0.00
Heavy Industrial	151.00	218.95	2905.24	19328.00	120045.00	250.66	31.71
<b>TOTAL</b>	<b>228.00</b>	<b>225.11</b>	<b>2951.44</b>	<b>20021.00</b>	<b>138140.00</b>	<b>250.66</b>	<b>31.71</b>

**Total Estimated Impervious: 53% in this analysis**

Any stormwater plan developed for this project will need to address how stormwater impacts will be controlled, including water quality, downstream channel protection and attenuation of peak flows to prevent downstream flooding. In order to address post-construction stormwater runoff quality, the project should implement stormwater management controls (structural and/or nonstructural) as found in the Georgia Stormwater Management Manual ([www.georgiastormwater.com](http://www.georgiastormwater.com)) and meet the stormwater management quantity and quality criteria outlined in the Manual.

## **HISTORIC RESOURCES**

**Will the proposed project be located near a national register site? If yes, identify site.**

None have been identified.

**In what ways could the proposed project create impacts that would damage the resource?**

Not applicable.

**In what ways could the proposed project have a positive influence on efforts to preserve or promote the historic resource?**

Not applicable.

## **INFRASTRUCTURE**

### **Transportation**

**How many site access points will be associated with the proposed development? What are their locations?**

The proposed development will have two access points to SR 74. The main access point will be on Cooper Circle (north), between SR 54 to the north and SR 85 to the south. This full movement signalized driveway will consist of one ingress lane and one exclusive left-turn egress lane and one shared through/right egress lane. A secondary access point is proposed south of the primary access at Cooper Circle (south). This full movement stop unsignalized driveway will consist of one ingress lane,

<b>Preliminary Report:</b>	May 5, 2008	<b>DEVELOPMENT OF REGIONAL IMPACT REVIEW REPORT</b>	<b>Project:</b>	SANY America #1779
<b>Final Report Due:</b>	June 4, 2008		<b>Comments Due By:</b>	May 19, 2008

and one exclusive right-turn egress lane and one share through/left-turn egress lane. A multi-use path is proposed to connect the site via a multi-use tunnel under SR 74 south of the site.

**How much traffic (both average daily and peak am/pm) will be generated by the proposed project?**

Carter Burgess Jacobs performed the transportation analysis. GRTA and ARC review staff agreed with the methodology and assumptions used in the analysis. The net trip generation is based on the rates published in the 7<sup>th</sup> edition of the Institute of Transportation Engineers (ITE) Trip Generation report; they are listed in the following table:

Land Use	A.M. Peak Hour			P.M. Peak Hour			24-Hour
	Enter	Exit	2-Way	Enter	Exit	2-Way	2-Way
Manufacturing 325 employees	95	35	130	62	68	130	865
<i>Mixed-Use Reductions</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>
<i>Alternative Mode Reductions</i>	<i>-2</i>	<i>-1</i>	<i>-3</i>	<i>-1</i>	<i>-1</i>	<i>-2</i>	<i>-17</i>
<i>Pass-By Reductions</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>	<i>n/a</i>
<b>TOTAL NEW TRIPS</b>	<b>93</b>	<b>35</b>	<b>217</b>	<b>61</b>	<b>67</b>	<b>128</b>	<b>848</b>

**What are the existing traffic patterns and volumes on the local, county, state and interstate roads that serve the site?**

Incorporating the trip generation results, the transportation consultant distributed the traffic on the current roadway network. An assessment of the existing Level of Service (LOS) and projected LOS based on the trip distribution findings helps to determine the study network. The results of this exercise determined the study network, which has been approved by ARC and GRTA. If analysis of an intersection or roadway results in a substandard LOS "D", then the consultant recommends improvements.

Projected traffic volumes from the Regional Travel Demand Model are compared to the assigned capacity of facilities within the study network. This data is used to calculate a volume to capacity (V/C) ratio. The V/C ratio values that define the LOS thresholds vary depending on factors such as the type of terrain traversed and the percent of the road where passing is prohibited. LOS A is free-flow traffic from 0 to 0.3, LOS B is decreased free-flow from 0.31 to 0.5, LOS C is limited mobility from 0.51 to 0.75, LOS D is restricted mobility from 0.76 to 0.9, LOS E is at or near capacity from 0.91 to 1.00, and LOS F is breakdown flow with a V/C ratio of 1.01 or above. As a V/C ratio reaches 0.8, congestion increases. The V/C ratios for traffic in various network years are presented in the following table. Any facilities that have a V/C ratio of 1.0 or above are considered congested.

<b>Preliminary Report:</b>	May 5, 2008	<b>DEVELOPMENT OF REGIONAL IMPACT REVIEW REPORT</b>	<b>Project:</b>	SANY America #1779
<b>Final Report Due:</b>	June 4, 2008		<b>Comments Due By:</b>	May 19, 2008

**V/C Ratios - to be determined during review**

**List the transportation improvements that would affect or be affected by the proposed project.**

**2008-2013 TIP\***

ARC Number	Route	Type of Improvement	Scheduled Completion Year
FA-074B1	SR 74 from SR 85 to south of Crosstown Drive	General Purpose Roadway Capacity	2009
FA-074B2	SR 74 at Flat Creek	Bridge Capacity	2009
FA-253	TDK Boulevard extension from McIntosh Trail in Coweta County to Dividend Drive in Peachtree City	General Purpose Roadway Capacity	2010
FA-AR-BP024	SR 74 multi-use path connections	Bicycle/Pedestrian Facilities	2010

**Envision6 RTP (Long Range Projects)\***

ARC Number	Route	Type of Improvement	Scheduled Completion Year
	*No long range projects in the vicinity*		

*\*The ARC Board adopted the Envision6 RTP and FY 2008-2013 TIP on September 26<sup>th</sup>, 2007.*

**Summarize the transportation improvements as recommended by consultant in the traffic study for SANY America.**

According to the findings, there will be no capacity deficiencies as a result of future year **background** traffic. The transportation consultant has made no recommendations for improvements to be carried out in order to upgrade the existing level of service.

According to the findings, there will be no capacity deficiencies as a result of future year **total** traffic. The transportation consultant has made no recommendations for improvements to be carried out in order to upgrade the existing level of service.

**Is the site served by transit? If so, describe type and level of service and how it will enhance or be enhanced by the presence of transit? Are there plans to provide or expand transit service in the vicinity of the proposed project?**

No transit is available in the area.

**What transportation demand management strategies does the developer propose (carpool, flex-time, transit subsidy, etc.)?**

The developer is proposing to include bicycle parking with shower facilities as well as parking reserved for golf carts in order facilitate non SOV trips.

<b>Preliminary Report:</b>	May 5, 2008	<b>DEVELOPMENT OF REGIONAL IMPACT REVIEW REPORT</b>	<b>Project:</b>	SANY America #1779
<b>Final Report Due:</b>	June 4, 2008		<b>Comments Due By:</b>	May 19, 2008

The development **PASSES** the ARC's Air Quality Benchmark test.

<b>Air Quality Impacts/Mitigation (based on ARC strategies)</b>	<b>Credits</b>	<b>Total</b>
Clean-fueled vehicles 2% per ea.10% of fleet	10%	10%
Transportation Management Association or Parking Management program	3%	3%
Bike/ped networks connect to adjoining uses	2%	2%
<b>Total Calculated ARC Air Quality Credits (15 % reduction required)</b>		<b>15%</b>

**What are the conclusions of this review? Is the transportation system (existing and planned) capable of accommodating these trips?**

- ARC staff has no transportation related comments/recommendations for the proposed development.

## **INFRASTRUCTURE**

### **Wastewater and Sewage**

Wastewater is estimated at .2 MGD based on information submitted for the review.

**Which facility will treat wastewater from the project?**

Line Creek Treatment Plant will provide wastewater treatment for the proposed development.

**What is the current permitted capacity and average annual flow to this facility?**

The capacity of Line Creek Site is listed below:

<b>PERMITTED CAPACITY MMF, MGD <sup>1</sup></b>	<b>DESIGN CAPACITY MMF, MGD</b>	<b>2001 MMF, MGD</b>	<b>2008 MMF, MGD</b>	<b>2008 CAPACITY AVAILABLE +/-, MGD</b>	<b>PLANNED EXPANSION</b>	<b>REMARKS</b>
2	2	1.23	2	0	Upgrade to all for reuse and seasonal discharge by 2004.	

*MMF: Maximum Monthly Flow. Mgd: million of gallons per day.*

<sup>1</sup> Source: Metropolitan North Georgia Water Planning District **SHORT-TERM WASTEWATER CAPACITY PLAN**, August 2002.

Preliminary Report:	May 5, 2008	<b>DEVELOPMENT OF REGIONAL IMPACT <u>REVIEW REPORT</u></b>	Project:	SANY America #1779
Final Report Due:	June 4, 2008		Comments Due By:	May 19, 2008

**What other major developments will be served by the plant serving this project?**

ARC has reviewed a number of major developments that will be served by this plant.

**INFRASTRUCTURE**

**Water Supply and Treatment**

**How much water will the proposed project demand?**

Water demand also is estimated at 0.2 MGD based on information submitted for the review.

**How will the proposed project's demand for water impact the water supply or treatment facilities of the jurisdiction providing the service?**

Information submitted with the review suggests that there is sufficient water supply capacity available for the proposed project.

**INFRASTRUCTURE**

**Solid Waste**

**How much solid waste will be generated by the project? Where will this waste be disposed?**

Information submitted with the review 500 tons of solid waste per year and the waste will be disposed of in Fayette County.

**Will the project create any unusual waste handling or disposal problems?**

No.

**Are there any provisions for recycling this project's solid waste.**

Yes, as part of the projects LEED certification, storage and collection of its recyclables are required.

**INFRASTRUCTURE**

**Other facilities**

**According to information gained in the review process, will there be any unusual intergovernmental impacts on:**

- Levels of governmental services?
- Administrative facilities?
- Schools?
- Libraries or cultural facilities?

Preliminary Report:	May 5, 2008	<b>DEVELOPMENT OF REGIONAL IMPACT <u>REVIEW REPORT</u></b>	Project:	SANY America #1779
Final Report Due:	June 4, 2008		Comments Due By:	May 19, 2008

- **Fire, police, or EMS?**
- **Other government facilities?**
- **Other community services/resources (day care, health care, low income, non-English speaking, elderly, etc.)?**

To be determined during the review.

## **HOUSING**

**Will the proposed project create a demand for additional housing?**

Yes, the proposed project will create a demand for additional housing.

**Will the proposed project provide housing opportunities close to existing employment centers?**

No.

**Is there housing accessible to the project in all price ranges demanded?**

The site proposed for the development is located in Census Tract 1403.06. This tract had a 9 percent increase in number of housing units from 2000 to 2007 according to ARC's Population and Housing Report. The report shows that 88 percent, respectively, of the housing units are single-family, compared to 69 percent for the region; thus indicating is a lack of multi-family housing options around the development area.

**Is it likely or unlikely that potential employees of the proposed project will be able to find affordable\* housing?**

Likely, assuming any future housing development is approved with multiple price ranges of housing.

\* Defined as 30 percent of the income of a family making 80 percent of the median income of the Region – FY 2000 median income of \$51,649 for family of 4 in Georgia.

# Developments of Regional Impact

[DRI Home](#) [DRI Rules](#) [Thresholds](#)
[Tier Map](#)
[FAQ](#) [Apply](#) [View Submissions](#) [Login](#)

DRI #1779

## DEVELOPMENT OF REGIONAL IMPACT Initial DRI Information

This form is to be completed by the city or county government to provide basic project information that will allow the RDC to determine if the project appears to meet or exceed applicable DRI thresholds. Refer to both the [Rules for the DRI Process](#) and the [DRI Tiers and Thresholds](#) for more information.

## Local Government Information

Submitting Local Government: Peachtree City

Individual completing form: David E. Rast, ASLA

Telephone: 770.487.5731

E-mail: [planner@peachtree-city.org](mailto:planner@peachtree-city.org)

\*Note: The local government representative completing this form is responsible for the accuracy of the information contained herein. If a project is to be located in more than one jurisdiction and, in total, the project meets or exceeds a DRI threshold, the local government in which the largest portion of the project is to be located is responsible for initiating the DRI review process.

## Proposed Project Information

Name of Proposed Project: SANY America - Peachtree City manufacturing facility (Phase 1)

Location (Street Address, GPS Coordinates, or Legal Land Lot Description): Cooper Circle (no address assigned yet) Peachtree City, GA 30269 GPS coordinates - 33° 20' 46" / 8

Brief Description of Project: SANY is based in China and is a worldwide manufacturer of heavy construction equipment. This development will include assembly/ office/ distribution facilities and will serve as SANY's North American headquarters.

## Development Type:

(not selected)	Hotels	Wastewater Treatment Facilities
Office	Mixed Use	Petroleum Storage Facilities
Commercial	Airports	Water Supply Intakes/ Reservoirs
Wholesale & Distribution	Attractions & Recreational Facilities	Intermodal Terminals
Hospitals and Health Care Facilities	Post-Secondary Schools	Truck Stops
Housing	Waste Handling Facilities	Any other development types

Industrial	Quarries, Asphalt & Cement Plants
If other development type, describe:	
Project Size (# of units, floor area, etc.):	Total of 570,486 SF (Phase 1), overall project site of 228 acres
Developer:	Mr. Jianguo (Jack) Tang/ Mr. Kevin M. Woods, Jr.
Mailing Address:	SANY America, Inc.
Address 2:	1180 Peachtree Street, NE, Suite 2618
	City:Atlanta State: GA Zip:30309
Telephone:	404.685.8318
Email:	TJG@sany.com.cn/ kevinmwoodsjr@bellsouth.net
Is property owner different from developer/ applicant?	(not selected) Yes No
If yes, property owner:	
Is the proposed project entirely located within your local government's jurisdiction?	(not selected) Yes No
If no, in what additional jurisdictions is the project located?	
Is the current proposal a continuation or expansion of a previous DRI?	(not selected) Yes No
If yes, provide the following information:	Project Name:
	Project ID:
The initial action being requested of the local government for this project:	Rezoning Variance Sewer Water Permit Other conceptual site plan approval
Is this project a phase or part of a larger overall project?	(not selected) Yes No
If yes, what percent of the overall project does this project/phase represent?	35%
Estimated Project Completion Dates:	This project/phase: October, 2009 Overall project: 5-10 years
<a href="#">Back to Top</a>	



# Developments of Regional Impact

[DRI Home](#)
[DRI Rules](#)
[Thresholds](#)
[Tier Map](#)
[FAQ](#)
[Apply](#)
[View Submissions](#)
[Login](#)

DRI #1779

## DEVELOPMENT OF REGIONAL IMPACT Additional DRI Information

This form is to be completed by the city or county government to provide information needed by the RDC for its review of the proposed DRI. Refer to both the [Rules for the DRI Process](#) and the [DRI Tiers and Thresholds](#) for more information.

### Local Government Information

Submitting Local Government: Peachtree City  
 Individual completing form: David E. Rast, ASLA  
 Telephone: 770.487.5731  
 Email: planner@peachtree-city.org

### Project Information

Name of Proposed Project: SANY America - Peachtree City manufacturing facility (Phase 1)  
 DRI ID Number: 1779  
 Developer/Applicant: Mr. Jianguo (Jack) Tang/ Mr. Kevin M. Woods, Jr.  
 Telephone: 678.936.1848  
 Email(s): kevinmwoodsjr@bellsouth.net

### Additional Information Requested

Has the RDC identified any additional information required in order to proceed with the official regional review process? (If no, proceed to Economic Impacts.)

(not selected)    Yes    No

If yes, has that additional information been provided to your RDC and, if applicable, GRTA?

(not selected)    Yes    No

If no, the official review process can not start until this additional information is provided.

### Economic Development

Estimated Value at Build-Out: \$70,000,000

Estimated annual local tax revenues (i.e., property tax, sales tax) likely to be generated by the proposed development:	\$30,000,000 by year 5
Is the regional work force sufficient to fill the demand created by the proposed project?	(not selected)    Yes    No
Will this development displace any existing uses?	(not selected)    Yes    No
If yes, please describe (including number of units, square feet, etc):	
<b>Water Supply</b>	
Name of water supply provider for this site:	Fayette County Water Department
What is the estimated water supply demand to be generated by the project, measured in Millions of Gallons Per Day (MGD)?	0.2 MGD
Is sufficient water supply capacity available to serve the proposed project?	(not selected)    Yes    No
If no, describe any plans to expand the existing water supply capacity:	
Is a water line extension required to serve this project?	(not selected)    Yes    No
If yes, how much additional line (in miles) will be required?	
<b>Wastewater Disposal</b>	
Name of wastewater treatment provider for this site:	Peachtree City Water and Sewerage Authority
What is the estimated sewage flow to be generated by the project, measured in Millions of Gallons Per Day (MGD)?	0.18 MGD
Is sufficient wastewater treatment capacity available to serve this proposed project?	(not selected)    Yes    No
If no, describe any plans to expand existing wastewater treatment capacity:	
Is a sewer line extension required to serve this project?	(not selected)    Yes    No
If yes, how much additional line (in miles) will be required?	
<b>Land Transportation</b>	

How much traffic volume is expected to be generated by the proposed development, in peak hour vehicle trips per day? (If only an alternative measure of volume is available, please provide.)	128 peak hour trips (PM)
Has a traffic study been performed to determine whether or not transportation or access improvements will be needed to serve this project?	(not selected)    Yes    No
Are transportation improvements needed to serve this project?	(not selected)    Yes    No
If yes, please describe below:	
<b>Solid Waste Disposal</b>	
How much solid waste is the project expected to generate annually (in tons)?	500 tons
Is sufficient landfill capacity available to serve this proposed project?	(not selected)    Yes    No
If no, describe any plans to expand existing landfill capacity:	
Will any hazardous waste be generated by the development?	(not selected)    Yes    No
If yes, please explain:	
<b>Stormwater Management</b>	
What percentage of the site is projected to be impervious surface once the proposed development has been constructed?	20%
Describe any measures proposed (such as buffers, detention or retention ponds, pervious parking areas) to mitigate the project's impacts on stormwater management: The site has been designed in accordance with the Georgia Stormwater Management Manual, including stormwater detention and stormwater quality treatment. Stormwater quality treatment is to be provided primarily by wet ponds, dry extended detention ponds, sand filters, and conservation areas. Buffers are provided around all streams and wetlands in accordance with local ordinances.	
<b>Environmental Quality</b>	
Is the development located within, or likely to affect any of the following:	
1. Water supply watersheds?	(not selected)    Yes    No


2. Significant groundwater recharge areas?	(not selected)	Yes	No
3. Wetlands?	(not selected)	Yes	No
4. Protected mountains?	(not selected)	Yes	No
5. Protected river corridors?	(not selected)	Yes	No
6. Floodplains?	(not selected)	Yes	No
7. Historic resources?	(not selected)	Yes	No
8. Other environmentally sensitive resources?	(not selected)	Yes	No
If you answered yes to any question above, describe how the identified resource(s) may be affected: A permit will be submitted seeking approval to fill and/ or pipe a small wetland associated with an intermittent stream that traverses a portion of the overall site.			
<a href="#">Back to Top</a>			

[GRTA Home Page](#) | [ARC Home Page](#) | [RDC Links](#) | [DCA Home Page](#) | [Site Map](#) | [Statements](#) | [Contact](#)

Copyright © 2007 The Georgia Department of Community Affairs. All Rights Reserved.



Executive  
Headquarters &  
Assembly Plant







SANY  
Sany America Inc.  
phone (404) 885-2512  
fax (404) 885-2516

It includes the:  
O&P Plan  
Manufacturing Facility  
Warehouse  
Office Building  
Visitor Entrance  
Employee/Truck Entrance  
Road A  
Road E  
Road F  
Road G  
Road H  
Road I  
Road J  
Road K  
Road L  
Road M  
Road N  
Road O  
Road P  
Road Q  
Road R  
Road S  
Road T  
Road U  
Road V  
Road W  
Road X  
Road Y  
Road Z  
Road AA  
Road AB  
Road AC  
Road AD  
Road AE  
Road AF  
Road AG  
Road AH  
Road AI  
Road AJ  
Road AK  
Road AL  
Road AM  
Road AN  
Road AO  
Road AP  
Road AQ  
Road AR  
Road AS  
Road AT  
Road AU  
Road AV  
Road AW  
Road AX  
Road AY  
Road AZ  
Road BA  
Road BB  
Road BC  
Road BD  
Road BE  
Road BF  
Road BG  
Road BH  
Road BI  
Road BJ  
Road BK  
Road BL  
Road BM  
Road BN  
Road BO  
Road BP  
Road BQ  
Road BR  
Road BS  
Road BT  
Road BU  
Road BV  
Road BW  
Road BX  
Road BY  
Road BZ  
Road CA  
Road CB  
Road CC  
Road CD  
Road CE  
Road CF  
Road CG  
Road CH  
Road CI  
Road CJ  
Road CK  
Road CL  
Road CM  
Road CN  
Road CO  
Road CP  
Road CQ  
Road CR  
Road CS  
Road CT  
Road CU  
Road CV  
Road CW  
Road CX  
Road CY  
Road CZ  
Road DA  
Road DB  
Road DC  
Road DD  
Road DE  
Road DF  
Road DG  
Road DH  
Road DI  
Road DJ  
Road DK  
Road DL  
Road DM  
Road DN  
Road DO  
Road DP  
Road DQ  
Road DR  
Road DS  
Road DT  
Road DU  
Road DV  
Road DW  
Road DX  
Road DY  
Road DZ  
Road EA  
Road EB  
Road EC  
Road ED  
Road EE  
Road EF  
Road EG  
Road EH  
Road EI  
Road EJ  
Road EK  
Road EL  
Road EM  
Road EN  
Road EO  
Road EP  
Road EQ  
Road ER  
Road ES  
Road ET  
Road EU  
Road EV  
Road EW  
Road EX  
Road EY  
Road EZ  
Road FA  
Road FB  
Road FC  
Road FD  
Road FE  
Road FF  
Road FG  
Road FH  
Road FI  
Road FJ  
Road FK  
Road FL  
Road FM  
Road FN  
Road FO  
Road FP  
Road FQ  
Road FR  
Road FS  
Road FT  
Road FU  
Road FV  
Road FW  
Road FX  
Road FY  
Road FZ  
Road GA  
Road GB  
Road GC  
Road GD  
Road GE  
Road GF  
Road GG  
Road GH  
Road GI  
Road GJ  
Road GK  
Road GL  
Road GM  
Road GN  
Road GO  
Road GP  
Road GQ  
Road GR  
Road GS  
Road GT  
Road GU  
Road GV  
Road GW  
Road GX  
Road GY  
Road GZ  
Road HA  
Road HB  
Road HC  
Road HD  
Road HE  
Road HF  
Road HG  
Road HH  
Road HI  
Road HJ  
Road HK  
Road HL  
Road HM  
Road HN  
Road HO  
Road HP  
Road HQ  
Road HR  
Road HS  
Road HT  
Road HU  
Road HV  
Road HW  
Road HX  
Road HY  
Road HZ  
Road IA  
Road IB  
Road IC  
Road ID  
Road IE  
Road IF  
Road IG  
Road IH  
Road II  
Road IJ  
Road IK  
Road IL  
Road IM  
Road IN  
Road IO  
Road IP  
Road IQ  
Road IR  
Road IS  
Road IT  
Road IU  
Road IV  
Road IW  
Road IX  
Road IY  
Road IZ  
Road JA  
Road JB  
Road JC  
Road JD  
Road JE  
Road JF  
Road JG  
Road JH  
Road JI  
Road JJ  
Road JK  
Road JL  
Road JM  
Road JN  
Road JO  
Road JP  
Road JQ  
Road JR  
Road JS  
Road JT  
Road JU  
Road JV  
Road JW  
Road JX  
Road JY  
Road JZ  
Road KA  
Road KB  
Road KC  
Road KD  
Road KE  
Road KF  
Road KG  
Road KH  
Road KI  
Road KJ  
Road KK  
Road KL  
Road KM  
Road KN  
Road KO  
Road KP  
Road KQ  
Road KR  
Road KS  
Road KT  
Road KU  
Road KV  
Road KW  
Road KX  
Road KY  
Road KZ  
Road LA  
Road LB  
Road LC  
Road LD  
Road LE  
Road LF  
Road LG  
Road LH  
Road LI  
Road LJ  
Road LK  
Road LL  
Road LM  
Road LN  
Road LO  
Road LP  
Road LQ  
Road LR  
Road LS  
Road LT  
Road LU  
Road LV  
Road LW  
Road LX  
Road LY  
Road LZ  
Road MA  
Road MB  
Road MC  
Road MD  
Road ME  
Road MF  
Road MG  
Road MH  
Road MI  
Road MJ  
Road MK  
Road ML  
Road MM  
Road MN  
Road MO  
Road MP  
Road MQ  
Road MR  
Road MS  
Road MT  
Road MU  
Road MV  
Road MW  
Road MX  
Road MY  
Road MZ  
Road NA  
Road NB  
Road NC  
Road ND  
Road NE  
Road NF  
Road NG  
Road NH  
Road NI  
Road NJ  
Road NK  
Road NL  
Road NM  
Road NN  
Road NO  
Road NP  
Road NQ  
Road NR  
Road NS  
Road NT  
Road NU  
Road NV  
Road NW  
Road NX  
Road NY  
Road NZ  
Road OA  
Road OB  
Road OC  
Road OD  
Road OE  
Road OF  
Road OG  
Road OH  
Road OI  
Road OJ  
Road OK  
Road OL  
Road OM  
Road ON  
Road OO  
Road OP  
Road OQ  
Road OR  
Road OS  
Road OT  
Road OU  
Road OV  
Road OW  
Road OX  
Road OY  
Road OZ  
Road PA  
Road PB  
Road PC  
Road PD  
Road PE  
Road PF  
Road PG  
Road PH  
Road PI  
Road PJ  
Road PK  
Road PL  
Road PM  
Road PN  
Road PO  
Road PP  
Road PQ  
Road PR  
Road PS  
Road PT  
Road PU  
Road PV  
Road PW  
Road PX  
Road PY  
Road PZ  
Road QA  
Road QB  
Road QC  
Road QD  
Road QE  
Road QF  
Road QG  
Road QH  
Road QI  
Road QJ  
Road QK  
Road QL  
Road QM  
Road QN  
Road QO  
Road QP  
Road QQ  
Road QR  
Road QS  
Road QT  
Road QU  
Road QV  
Road QW  
Road QX  
Road QY  
Road QZ  
Road RA  
Road RB  
Road RC  
Road RD  
Road RE  
Road RF  
Road RG  
Road RH  
Road RI  
Road RJ  
Road RK  
Road RL  
Road RM  
Road RN  
Road RO  
Road RP  
Road RQ  
Road RR  
Road RS  
Road RT  
Road RU  
Road RV  
Road RW  
Road RX  
Road RY  
Road RZ  
Road SA  
Road SB  
Road SC  
Road SD  
Road SE  
Road SF  
Road SG  
Road SH  
Road SI  
Road SJ  
Road SK  
Road SL  
Road SM  
Road SN  
Road SO  
Road SP  
Road SQ  
Road SR  
Road SS  
Road ST  
Road SU  
Road SV  
Road SW  
Road SX  
Road SY  
Road SZ  
Road TA  
Road TB  
Road TC  
Road TD  
Road TE  
Road TF  
Road TG  
Road TH  
Road TI  
Road TJ  
Road TK  
Road TL  
Road TM  
Road TN  
Road TO  
Road TP  
Road TQ  
Road TR  
Road TS  
Road TT  
Road TU  
Road TV  
Road TW  
Road TX  
Road TY  
Road TZ  
Road UA  
Road UB  
Road UC  
Road UD  
Road UE  
Road UF  
Road UG  
Road UH  
Road UI  
Road UJ  
Road UK  
Road UL  
Road UM  
Road UN  
Road UO  
Road UP  
Road UQ  
Road UR  
Road US  
Road UT  
Road UY  
Road UZ  
Road VA  
Road VB  
Road VC  
Road VD  
Road VE  
Road VF  
Road VG  
Road VH  
Road VI  
Road VJ  
Road VK  
Road VL  
Road VM  
Road VN  
Road VO  
Road VP  
Road VQ  
Road VR  
Road VS  
Road VT  
Road VY  
Road VZ  
Road WA  
Road WB  
Road WC  
Road WD  
Road WE  
Road WF  
Road WG  
Road WH  
Road WI  
Road WJ  
Road WK  
Road WL  
Road WM  
Road WN  
Road WO  
Road WP  
Road WQ  
Road WR  
Road WS  
Road WT  
Road WY  
Road WZ  
Road XA  
Road XB  
Road XC  
Road XD  
Road XE  
Road XF  
Road XG  
Road XH  
Road XI  
Road XJ  
Road XK  
Road XL  
Road XM  
Road XN  
Road XO  
Road XP  
Road XQ  
Road XR  
Road XS  
Road XT  
Road XU  
Road XV  
Road XW  
Road XX  
Road XY  
Road XZ  
Road YA  
Road YB  
Road YC  
Road YD  
Road YE  
Road YF  
Road YG  
Road YH  
Road YI  
Road YJ  
Road YK  
Road YL  
Road YM  
Road YN  
Road YO  
Road YP  
Road YQ  
Road YR  
Road YS  
Road YT  
Road YU  
Road YV  
Road YW  
Road YX  
Road YY  
Road YZ  
Road ZA  
Road ZB  
Road ZC  
Road ZD  
Road ZE  
Road ZF  
Road ZG  
Road ZH  
Road ZI  
Road ZJ  
Road ZK  
Road ZL  
Road ZM  
Road ZN  
Road ZO  
Road ZP  
Road ZQ  
Road ZR  
Road ZS  
Road ZT  
Road ZU  
Road ZV  
Road ZW  
Road ZX  
Road ZY  
Road ZZ

SITE PLAN NOTES:

- A. SITE: SANY MANUFACTURING FACILITY  
COOPER LOOP ROAD  
PEACHTREE CITY, GA 30269
- B. OWNER: SANY GROUP CO. LTD.  
1180 PEACHTREE STREET NE  
ATLANTA, GA 30309
- C. ARCHITECT: PERKINS AND WILL  
300 N. LAKE STREET NE  
ATLANTA, GEORGIA 30309  
CONTACT: DON RENOLDS (404) 443-7807
- D. ENGINEER: INTEGRATED SCIENCE & ENGINEERING  
1180 PEACHTREE STREET NE  
ATLANTA, GEORGIA 30309  
CONTACT: JASON WALLS, P.E. (770) 461-4292
- E. WETLANDS ECOLOGICAL CONSULTANTS: WETLANDS AND ECOLOGICAL CONSULTANTS, LLC.  
3225 SOUTH CHEROKEE LANE  
WOODSTOCK, GA 30188
- F. SEE SHEET G101 FOR ADDITIONAL SITE PLAN NOTES. SHALL VERIFY ALL BUILDING DIMENSIONS WITH THE ARCHITECTURAL PLANS. BUILDING FOOTPRINT SHOWN FOR SITE LAYOUT PURPOSES ONLY.
- H. SITE DATA:  
ZONING: G  
TOTAL SITE AREA = 228 AC.
- I. BUILDING SUMMARY:  
MANUFACTURING OF ENGINEERING MACHINERY  
DENSITY: 360,000 SF / 228 AC. / AC.  
DISTRIBUTION BUILDING: 107,639 S.F.  
DISTRIBUTION CENTER OF ENGINEERING MACHINERY  
DENSITY: 107,639 SF / 228 AC. / AC.  
OFFICE BUILDING: 139,930 S.F.  
RESEARCH AND DEVELOPMENT, OPERATIONS, RESTING  
DENSITY: 139,930 SF / 228 AC. / AC.  
TOTAL BUILDING: 607,569 S.F.  
TOTAL DENSITY: 2,664.79 SF BLDG. / AC.  
TOTAL OPEN SPACE: 116.91 ACRES
- J. BUFFERS:  
STREET: 25'  
STREAM: 50'  
IMPERVIOUS: 75'  
SETBACKS:  
STREET: 50'  
STREAM: 20'  
REAR: 20'
- K. PARKING SUMMARY:  
PARKING REQUIREMENTS:  
ASSEMBLY BUILDING: 280 SPACES PROVIDED  
DISTRIBUTION BUILDING: 88 SPACES PROVIDED  
TOTAL BLDG SPACES: 368 SPACES PROVIDED  
TOTAL HANDICAP SPACES: 21  
TOTAL GOV. CART SPACES: 11  
PARKING STALL DATA: 6' x 14' ADJACENT MEDIANS  
GOV. CART STALL: 6' x 10'
- L. ALTERNATIVE TRANSPORTATION SUMMARY:  
PUBLIC TRANSPORTATION ACCESS: NOT AVAILABLE  
BIKEWAY: NOT AVAILABLE (40 SPACES)  
LOW EMITTING & FUEL EFFICIENT VEHICLES: AVAILABLE (20 SPACES)  
PARKING CAPACITY/CARPOOLS: AVAILABLE (20 SPACES)  
IMPERVIOUS SURFACE CALCULATIONS:  
ALLOWED: 60% TOTAL SITE AREA  
60' x 228' = 136.8 AC. MAX.  
TOTAL: 79.8 AC. (35%)



- SITE PLAN LEGEND:
- PROPERTY LINE - SEE PLAT FOR DETAILS
  - SETBACK LINE - SEE PLAT FOR DETAILS
  - LANDLOT LINE
  - EXISTING ROAD
  - CONCRETE PAVEMENT - SEE DETAIL ON SHEET C700
  - CURB AND GUTTER - SEE DETAIL ON SHEET C700
  - STREAM
  - WETLANDS
  - AREA WITHIN EXISTING FEMA 100 YEAR FLOOD PLAIN-100 YEAR FLOOD PLAIN SHOWN WAS FIELD RUN AND LOCATED USING 2007 FLOOD DATA
  - LIMITS OF OPEN SPACE
  - MULTI-PURPOSE PATH

